

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Monitoring Requirements Not Met for Milwaukee County Grounds**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. Between 08/03/2021 and 08/13/2021, we did not monitor for **disinfection byproduct contaminants, and therefore cannot be sure of the quality of your drinking water during that time.**

**What precautions should be taken at this time?**

There are no special precautions you need to take at this time. The samples were taken on 8/30/2021 and the results were well below action levels required by the Department of Natural Resources.

**What was the cause of the missed monitoring requirements?**

Sample bottles were shipped to the Thermal Plant and were misplaced in the receiving area. Utility staff did not have a calendar listing the sampling requirements to serve as a reminder for these important dates.

**What is being done to correct the problem?**

Disinfection By Product sample dates are now written down on a wall calendar in the office. Utility staff has a visual reminder of the sampling window when they arrive at the office every day.

**When will the problem be resolved?**

The samples were collected on 8/30/2021 and the results were well below action levels set by the Wisconsin Department of Natural Resources. This notification will bring us back into compliance with the Wisconsin Department of Natural Resources.

**If you have questions regarding the safety of our drinking water, please contact:**

Jim Voigt

414-559-8656

Name of Responsible Person

Area Code-Telephone Number

9250 W Watertown Plank Rd

Wauwatosa

WI 53226

Street Address

City

State Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter VII of ch. NR 809, Wis. Adm. Code.



Signature

11/5/2021

Date

\*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.